

Sedona Sun Series

PA200VL-PA200L



Description

Ventilating fan shall be a quiet ceiling mount type rated for continuous run. Fan shall be tested as per AMCA or the Home Ventilating Institute (HVI) standards. Evaluated by ETL and conform to UL safety standards.

Motor/Blower:

- . Plug in, permanently lubricated motor.
- . Power Rating shall be 120 volts and 60 hz.
- . Quiet operation, polymeric blower wheel, See Chart for performance

Housing:

- . Galvanized steel housing
- . Noiseless detachable 4" diameter duct adapter.
- . Built in backdraft damper.
- . Mounts directly to joist using brackets. .
- . Housing Dimensions: See Chart

Grille:

- . Attractive white polymeric grille

Bulb Heater:

- . 250 Watt Infrared Bulbs (not included)



. Ventilating fan shall be of the ceiling mount with no less than air performance and sound rating as per the following chart tested as per either AMCA or the Home Ventilating Institute (HVI) standards at 0.1" static pressure in inches water gauge. The motor shall be plug in and permanently lubricated. Power rating shall be 120v/60Hz. Duct diameter shall be no less than 4". Heater and ventilator can be operated separately or in combination.



| MODEL | CFM @ .1" SP | Sones @ .1" SP | Consumption | Insulation | Grille | Housing |
|--------------------------|--------------|----------------|-------------|------------|-------------------|------------------------|
| PA200VL | 70 | 3.5 | 250 Watts | R40/BR40 | 15 5/8" x 10 1/4" | 14 1/4" x 10 1/8" x 6" |
| PA200L (Heater less fan) | n/a | n/a | 250 Watts | R40/BR40 | 15 5/8" x 10 1/4" | 14 1/4" x 10 1/8" x 6" |

| Model | Quantity | Comments | Project: |
|-------|----------|----------|---------------|
| | | | Location: |
| | | | Architect: |
| | | | Engineer: |
| | | | Contractor: |
| | | | Submitted by: |



Lexton Industries, Inc.,
 5681 S. Downey Road,
 Vernon, CA 90058
 Phone: 323-284-2188
 Toll Free Fax: 866-281-8605
 www.lextonfans.com